REPORT ON BIO-MEDICAL WASTE MANAGEMENT FOR THE MONTH OF NOVEMBER, 2023

7					5	4		ω		2	1	Sl. No.
c) Total nos. And capacity of each treatment equipment (in Kg/day)	b)Details of treatment equipment	a)Bio-medical waste treated (in Kg/day)	In case, HCF is having captive treatment facility,	Name and address of the CBWTF through which waste is disposed off (as applicable)	Mode of disposal of bio-medical waste (through CBWTF or through captive treatment facility)	Quantity of bio-medical waste generation (in Kg/day)	b) Consent under Water (Prevention and Control of Pollution) Act, 1974 and Air(Prevention and Control of Pollution) Act, 1981	a) Authorisation under BMWM Rules, 2016	Details of:	No. of Beds	Contact Address and details of the Healthcare Facility	Description
i) Incinerator- 1 No. Capacity: 10-12 Kg/hr ii) Autoclave – 1 No. Capacity: 78 litres iii) Shredder - 1 No. Capacity 50-100 kg iv) Needle Destroyer – 12 Nos. — Capacity: 4000 litre/day	 i) Incinerator ii) Autoclave iii) Shredder iv) Needle Destroyer v) ETP (Effluent Treatment Plant) 	9.5 Kg		N/A	Through captive treatment facility	9.5 Kg	Authorization No: WB/TEZ/T-2189/22-23/14 dtd. 11/11/22	Applied for, Application no: 444804 dated,12/03/2021 Previous authorization No: WB/OTWA/BMW-448/18-19/01/170		336 No.	LGB Regional Institute of Mental Health, Tezpur, Sonitpur, Assam, Pin-784001, Tele No. 03712-232652, fax No 03712-233623	Remarks

\$ Ottober

9	8									
year year	Monthly records of biomedical waste generation(category wise)	d) Operating parameters of the treatment equipment as per BMWM Rules, 2016								
	 i) Yellow category: 61.381 kg/month ii) Red category: 157.13 kg/month iii) White category: 9.293 kg/month iv) Blue category: 52.338 kg/month 	i) Monitors steam processes with Geobacillus stearothermophilus spores. ii) Steam Indicator tape	2) Autoclave: (Gravity flow)	Temperature Primary Chamber 800° ± 50° C, Secondary Chamber 1000° ± 50° C Height- 30 meters above from the ground Capacity- 10-12 Kg/hr	1) Incinerator SI. No. Parameter Result i. SO ₂ (ppm) 17.5 ii. NO ₂ (ppm) 37.5 iii. HCI (mg/Nm3) 29 iv. CO (ppm) 286 v. CO ₂ % 8.2					

I/C Central Laboratory
LGBRIMH, Tezpur