

REPORT ON BIO-MEDICAL WASTE MANAGEMENT FOR THE MONTH OF AUGUST, 2024

Sl. No.	Description	Remarks
1	Contact Address and details of the Healthcare Facility	LGB Regional Institute of Mental Health, Tezpur, Sonitpur, Assam, Pin-784001, Tele No. 03712-232652, fax No.- 03712-233623 336 No.
2	No. of Beds	
	Details of :	
3	a) Authorisation under BMWM Rules, 2016 b) Consent under Water (Prevention and Control of Pollution) Act, 1974 and Air(Prevention and Control of Pollution) Act, 1981 4 Quantity of bio-medical waste generation (in Kg/day)	Applied for, Application no: 444804 dated,12/03/2021 Previous authorization No: WB/OTWA/BMW-448/18-19/01/170 Authorization No: WB/TEZ/T-2189/22-23/14 dtd. 11/11/22
5	Mode of disposal of bio-medical waste (through CBWTF or through captive treatment facility)	8.206 Kg
6	Name and address of the CBWTF through which waste is disposed off (as applicable) In case, HCF is having captive treatment facility,	Through captive treatment facility N/A
	a)Bio-medical waste treated (in Kg/day)	8.206 Kg
	b)Details of treatment equipment	i) Incinerator ii) Autoclave iii) Shredder iv) Needle Destroyer v) ETP (Effluent Treatment Plant)
7		i) Incinerator- 1 No. Capacity: 10-12 Kg/hr ii) Autoclave – 1 No. Capacity : 78 litres iii) Shredder - 1 No. Capacity 50-100 kg iv) Needle Destroyer – 12 Nos. — v) ETP – 1 No Capacity: 4000 litre/day
	c) Total nos. And capacity of each treatment equipment (in Kg/day)	

		<p>1) <u>Incinerator</u></p> <table border="1"> <thead> <tr> <th>Sl. No.</th><th>Parameter</th><th>Result</th></tr> </thead> <tbody> <tr> <td>i.</td><td>SO_2 (ppm)</td><td>17.5</td></tr> <tr> <td>ii.</td><td>NO_2 (ppm)</td><td>37.5</td></tr> <tr> <td>iii.</td><td>HCl (mg/Nm³)</td><td>29</td></tr> <tr> <td>iv.</td><td>CO (ppm)</td><td>286</td></tr> <tr> <td>v.</td><td>CO_2 %</td><td>8.2</td></tr> </tbody> </table>	Sl. No.	Parameter	Result	i.	SO_2 (ppm)	17.5	ii.	NO_2 (ppm)	37.5	iii.	HCl (mg/Nm ³)	29	iv.	CO (ppm)	286	v.	CO_2 %	8.2
Sl. No.	Parameter	Result																		
i.	SO_2 (ppm)	17.5																		
ii.	NO_2 (ppm)	37.5																		
iii.	HCl (mg/Nm ³)	29																		
iv.	CO (ppm)	286																		
v.	CO_2 %	8.2																		
d) Operating parameters of the treatment equipment as per BMWM Rules, 2016		<p><u>Temperature</u> Primary Chamber $800^{\circ} \pm 50^{\circ}$ C, Secondary Chamber $1000^{\circ} \pm 50^{\circ}$ C <u>Height</u>- 30 meters above from the ground <u>Capacity</u>- 10-12 Kg/hr</p> <p>2) <u>Autoclave: (Gravity flow)</u></p> <ul style="list-style-type: none"> i) Monitors steam processes with Geobacillus stearothermophilus spores. ii) Steam Indicator tape 																		
8	Monthly records of biomedical waste generation(category wise)	<ul style="list-style-type: none"> i) Yellow category : 65.535 kg/month ii) Red category : 131.324 kg/month iii)White category : 7.784 kg/month iv) Blue category : 41.547 kg/month 																		
9	No. of trainings conducted on Bio-medical Waste management in the current year	36																		

S. Kumar 09/10/19
IIC Central Laboratory
LGBRIMH, Tezpur